



Request for Information - RFI 003 Response

Village Meadows, Sierra Vista, AZ

Project Name: Village Meadows Baptist Church
BGW Project Number: AC489

General Contractor: Cochise Tech & Development

Date Responded: 10.11.17

Requested Information: Roofing system?

Response:

The roofing system is as indicated on the roof plan sheet A108. APO 5 ply Elastomeric roof system (Apox #AMI-PA-252 specification) with MAT-40 moisture barrier underlayment over r-30 polyiso insulation. This was specifically requested by the owner.

Supplemental Drawings Attached:

Response By: Adrian Ben. BGW