



Request for Information - RFI 004

Response

Village Meadows, Sierra Vista, AZ

Project Name: Village Meadows Baptist Church
BGW Project Number: AC489

General Contractor: Cochise Tech & Development

Date Responded: 10.18.17

Requested Information: Is AC Foam II roof insulation acceptable?

Response:

Atlas AC Foam II with a minimum 25 psi with an R-30 value will be acceptable.

Supplemental Drawings Attached:

Response By: Adrian Ben. BGW